



# 2021 Landowner Commingling Interest Well Inspection

Well Owner \_\_\_\_\_

Parcel No. \_\_\_\_\_ Database Seq. No. \_\_\_\_\_

All Water User wells used pursuant to this Wheeling Agreement for Private Well Water Supply must meet the following minimum standards before pumping commences:

### Safety Criteria

Selected wells must comply with current Industrial Safety Standards. Required safety measures include but are not limited to the following:

- Does the engine have driveline, belt and pulley guards? Yes  No
- Does the engine have drip/catch pans in place? Yes  No
- Are meters, well sounding tubes, and water quality sampling sites unobstructed by moving parts, heat exchangers, sharp objects and slippery surfaces? Yes  No

### Flow Measurement Specifications

The production well outlet conduit must be equipped with a flow meter that meets the following criteria:

- Flow meter has a  $\pm 5\%$  manufacturer's certified accuracy? Yes  No
- Instantaneous flow rate and cumulative volume totalizer? Yes  No
- Is the flow totalizer accessible to GCID staff for inspection at any time? Yes  No
- Meter **10** pipe diameters downstream of any appurtenance (well, elbow, or valve) and **5** diameters upstream of any appurtenance or outlet? Yes  No

### OR

- Installed in accordance with meter manufacturer's placement specifications? Yes  No
- \_\_\_\_\_ Upstream diameters \_\_\_\_\_ Downstream diameters

### OR

- Flow straightening vanes installed to reduce necessary upstream and downstream spacing in accordance with manufacturer's specifications? Yes  No
- \_\_\_\_\_ Upstream diameters \_\_\_\_\_ Downstream diameters

**Prior To Well Pumping**

- Well discharge system satisfies GCID standards? Yes  No
- Photograph of well. Yes  No
- Photograph of meter and meter total. Yes  No   
    **Meter reading** \_\_\_\_\_ Ac-ft
- Meter Manufacturer & type (If available) \_\_\_\_\_
- Groundwater level – distance from reference point to water surface level. \_\_\_\_\_ft.
- Did Landowner supply a Well Completion Report? Yes  No   
    If Yes, Well Completion Report Number \_\_\_\_\_

**Post Well Shut Down**

- Photograph of meter and meter total. Yes  No   
    **Meter reading** \_\_\_\_\_ Ac-ft
- Groundwater level – distance from reference point to water surface level. \_\_\_\_\_ft.

**Comments:**

---

---

---

---

---

---

---

---

*Inspected by:*

_____	_____	_____
Print Name	Signature	Date

*Final approval by:*

_____	_____	_____
Print Name	Signature	Date